

Performance Annual Report

I. General Information

Facility/System Name: Mount Holly Wastewater Treatment Works
Responsible Entity: City of Mount Holly
Person in Charge/Contact: B.W. Eller, Deputy Public Works Director
Applicable Permits(s): NC0021156 - NPDES WWTP Permit
NCCS00059 - NPDES Collection System Permit

Description of Collection System and Treatment Process:

The City of Mount Holly owns and maintains a collection and treatment system consisting of approximately 83 miles of gravity mains, lifts stations, and force mains flowing to a 4.0 Million Gallon per Day extended aeration treatment plant.

II. Performance

Text Summary of System Performance for the fiscal year from July 1, 2010 to June 30, 2011

The City of Mount Holly strives for compliance with all of the continually expanding requirements of the State and Federal regulations while maintaining some of the lowest utility rates in North Carolina. During routine inspections of the City's facilities, State inspectors often make recommendations for improvement which the City promptly implements or corrects. Most of the improvements or deficiencies that they find are regarding record-keeping and not directly related to impact to the environment. The City continues to provide resources and personnel to meet the State's requirements. Below is a list, by month, of reportable incidents.

March 2011 Monthly Est. Volume of Overflow to Stream- 6,250 gals.

03/07/11 Sanitary Sewer outfall behind 208 Autumn Woods Blvd- due to grease-overflow (2,650)

03/17/11 Between 166 & 167 Taylors Creek St- due to test plug left in line-overflow (1,200)

03/20/11 Manhole at 188 W Walnut Ave in roadway- due to debris in line-overflow (2,400)

May 2011 Monthly Est. Volume of Overflow to Stream- 125 gals.

05/27/11 398 Marina Village Dr- due to Pump Station equipment power outage-Overflow (125)


All pump stations have updated automatic dialers installed to notify personnel should problems arise. With our system we try to maintain an excellent response time to emergencies.

III. Notification

This report is posted at City Hall, 400 E. Central Ave., Mount Holly, NC 28120. Notice was published in the Banner News to inform users of its availability, and is also available at www.mtholly.us.

IV. Certification

I certify under penalty of law that this report is complete and accurate to the best of my knowledge. I further certify that this report has been made available to the users or customers of the named system and that those users have been notified of its availability.


B. W. Eller
Deputy Public Works Director
City of Mount Holly

7-1-11
Date